



Water Analysis Report

District Level Water Analysis Laboratory,

Uttar Pradesh Jal Nigam, (Rural), Ghazipur, 233001
(An NABL Accredited Laboratory)

Report No.	GZP/DW/26/05/199	Date	18/05/2026	Page No.	1/1
Customer Name	M/S. Ramdoot International School				
Office Name and Address	Mithanpara, Mishrawaliya, Rauza, Ghazipur				
Ref. Letter No. & Date					

Basic details of sample

District	Ghazipur	Block	Ghazipur
Gram Panchayat	Mithanpara, Mishrawaliya, Rauza	Village	Mithanpara, Mishrawaliya, Rauza
Habitation	Kapurpur	Location/Site Name	Mithanpara, Mishrawaliya, Rauza
Water Source	Drinking Water	Sample No.	199
Quality of Sample (ml)	2 L	Date of S.C.	16/05/2026
Receiving Date	16/05/2026	S. Collector	Client
Sample Depositor	Sanjay	Sampling Method	IS Method
Analysis Start Date	16/05/2026	Analysis completion date	18/05/2026
Longitude	83.8577	Latitude	25.8617
Temperature	24.8 °C	Relative Humidity	52%

Technical Data of Analysis


S. No.	Analyzed parameters	Units	Observed Value	Specified Values as per BIS		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	pH@25	-	7.01	6.5-8.5	No Rex	IS 3025 (Part 11): 2022 (Electrometric Method)
2	Turbidity	NTU	1.00	1	5	IS 3025 (Part 10): 2024
3	Total Dissolve Solid	Mg/L	202.00	500	2000	IS 3025 (Part 16): 2023 (Gravimetric method)
4	Chloride	Mg/L	72.00	250	1000	IS 3025 (Part 32): 2019 (Argentometric method)
5	Total Alkalinity	Mg/L	80.00	200	600	IS 3025 (Part 23): 2023 (Potentiometric and indicator method)
6	Total Hardness	Mg/L	82.00	200	600	IS 3025 (Part 21): 2019 (EDTA method)
7	Sulphate	Mg/L	0.23	200	400	APHA 24 th Edition 4500 So ₄ method E (Turbidity Method): 2023
8	Nitrate	Mg/L	0.32	45	No Rex	APHA 24 th Edition 4500 NO ₃ method B.(UV Spectrophotometric Method): 2023
9	Fluoride	Mg/L	0.12	1.0	1.5	APHA 24 th Edition 4500-F method C (Ion- selective Electrode Method): 2023
10	Iron	Mg/L	0.4	1.0	No Rex	APHA 24 th Edition 3500-Fe method B (Phenanthroline method): 2023
11	Calcium (as Ca)	Mg/L	28.00	75	200	IS 3025 (Part 40): 2024 (EDTA Titrimetric method)
12	Magnesium (as Mg)	Mg/L	12.43	30	100	IS 3025 (Part 46): 2023 (Volumetric method)
13	Odour	-	Agreeable	Agreeable	Agreeable	IS 3025 (Part 05): 2018
14	Taste	-	Agreeable	Agreeable	Agreeable	IS 3025 (Part 07&08): 2023
15	Coloure	Hazen	<5	5	15	IS 3025 (Part 4): 2021 or APHA 24 th Edition, 2120 B (Platinum Cobalt Visual comparison Method)


All these Parameters are under NABL Scope, BDL-Below Detection Limit, NA- Not Analyzed

Note 1. This certificate refers only to the particular sample(s) submitted for analysis.

- This certificate shall not be reproduced, excepted in full, unless written permission for the publication of an approved abstract has been obtained from Head of laboratory.
- The analysis results reported in this certificate are valid at the time of and under the stated condition of measurement.
- Sample(s) will be stored up to 07 days (in case of non-perishable items only) from the date of issue of analysis reports unless otherwise specified.
- Parameters above permissible Limit are written in bold
- Sample (s) with any parameter value above Accepted Limit will only be used for oral consumption, if no other source is available.
- Sample is not collected by lab.


Sanjay Kumar
(Report Prepared by)


Anshu Yadav
(Report Reviewed by)



Laboratory Contact details: Email ID- upjnslaboratoryghazipur@gmail.com, Mobile No: 7379721130

End of the Report

PROFOMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. - 16/26

Date: 18.05.2026

It is Certified that an inspection team headed by **Anshu Yadav / Quality Manager.**
(Name of officers with designation) from District Level Water Analysis Laboratory, U.P. Jal Nigam
(Rural) Ghazipur, (Name of Department/ Office) Inspected the Water of **M/S. Ramdoot**

International School

Mithanpara, Mishrawaliya, Rauza, Ghazipur

(Name & Address of the School) on 16.05.2026 (Date of inspection) and found that the basis of
water Test Report (Attached) bearing no. GZP/DW/26/05/199 dated 18.05.2026

M/S. Ramdoot International School

Mithanpara, Mishrawaliya, Rauza, Ghazipur

(Name of school) has safe drinking water Facilities for the students and members of staff of the
institution. School is also maintaining the hygienic sanitation condition in the school building & the
campus as per norms prescribed by the Central/State/ U.T. Govt.

The above is valid for a period of **06 Month**

Signature with Seal: .....

Name: Anshu Yadav

Designation: Assistant/Lab Incharge.

Name & Address of the Office / Department: UPJN(R)

To,

M/S. Ramdoot International School

Mithanpara, Mishrawaliya, Rauza, Ghazipur

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer/ PHED/local bodies